

Water Vapour Transmission Test Certificate

Tuesday, April 26th 2016

Supplier: Nordic Built Australia (PO Box 3151, Brighton, VIC, 3186)

Sample Description: NB2M-SU701

Date Tested: April 2016 (Tested by FORAY Laboratories)

Test Method: ASTM E96 "Standard Test Method for Water Vapor Transmission of Materials (water method)."

Water Resistance Data:

Sample Name	NB2M-SU701
Permeance (g/m²/day/mmHg)	0.1020
Permeance (g/m².s.Pa)	8.71 x 10⁻⁹
Sd Value (m)	20
Water vapour transmission (g/m².hr)	0.0843

The test was conducted by water method at 22±2°C and RH: 50±5%



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
B.E Chem.
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160419a

Water Vapour Transmission Test Certificate

Tuesday, April 26th 2016

Supplier: Nordic Built Australia (PO Box 3151, Brighton, VIC, 3186)

Sample Description: NB2M-SU701

Date Tested: April 2016 (Tested by FORAY Laboratories)

Test Method: ASTM E96 "Standard Test Method for Water Vapor Transmission of Materials (water method)."

Water Resistance Data:

Sample Name	Water Vapour Transmission (g/m ² /day/mmHg)
NB2M-SU701	0.1020



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
B.E Chem.
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160419